

BONITA UNIFIED SCHOOL DISTRICT
115 W Allen Avenue
San Dimas, CA 91773

ADDENDUM NO. 1

Bid Number 14-15:05

Walk-In Freezer at District Central Kitchen (Rebid)

Date: February 6, 2015

A Pre-Bid Conference was conducted at the above-referenced District Site at the Bonita Unified School District office on Friday, January 30, 2015. The general contents of the Walk-In Freezer specifications were reviewed during the job walk portion of the Pre-Bid Conference with the bidding Contractors.

The following changes shall be incorporated into the bidding documents.

Acknowledge receipt of this addendum on the space provided on the Bid Form.

ADDENDUM ITEMS:

1. **Revise:** Scope of Work:
 - a. **DELETE** 2 x 12 Redwood Breaker, revise with recessed floor (see attached) and a No Threshold heater.

CLARIFICATION ITEMS

1. CAM Down Ceiling is okay
2. Electrical under floor will be treated as an unforeseen extra
3. Due to manufacturer lead times, contract can be extended within reason.

If you have any questions pertaining to this addendum, please do not hesitate to call Anna G Hamilton, Director of Purchasing at (909) 971-8320 Ext. 5250.

cc: Rob Harrison, Sup. Trades/Gen. Maint.
Sue Kilgour, Food Services Director

RECESSED FLOOR SECTION

